

Mike Conklin
March 20, 2024

WILTON PUBLIC WORKS
DEPARTMENT

(203) 563-0153



TOWN HALL ANNEX
238 Danbury Road
Wilton, Connecticut 06897

TO: Mike Conklin

FROM: Stephen Santacroce, PE, - Senior Civil Engineer S.F.S.

DATE: March 20, 2024

CC: Steve Trinkaus, PE, Trinkaus Engineering
Frank Smeriglio, PE, Director of Public Works/Town Engineer

RE: 232 Silver Spring Road

The Department of Public Works reviewed site plans and an engineering summary letter dated November 29, 2023, received on January 8, 2024 for the above mentioned property. Based on the review at this time, the following items must be addressed:

- 1) Show all proposed grading and drains on the stormwater plan.
- 2) It is unclear in the report what area is being routed through the proposed cultech units. If it is the house roof area, please specify in the project description section of the report.
- 3) The discharge pipe from the proposed trench drain near the new pool area shall not drain to the surface and potentially flow onto the neighboring property.
- 4) Water discharge from the water softener into the proposed cultech unit on the south side of the house should be coordinated with the health department.
- 5) Provide details for the proposed boulder retaining wall.
- 6) Please note, prior to the issuance of Certificate of Occupancy, as-built drawing and certification letter from the Design Engineer shall be submitted prior to DPW approval.

If you have any questions, please do not hesitate to call.