

**WILTON PUBLIC WORKS
DEPARTMENT**

(203) 563-0153



**TOWN HALL ANNEX
238 Danbury Road
Wilton, Connecticut 06897**

MEMORANDUM

TO: Mike Conklin, Director, Environmental Affairs

FROM: Frank Smeriglio, PE, *FS*
Director of Public Works/Town Engineer

DATE: March 16, 2022

RE: 20 Deepwood Rd – Kelly
WET #2764(s)

Based on the review at this time of the above mentioned application submitted along with the transmittal letter dated February 28, 2022, the Department of Public Works Department has no objections with this application continuing with the approval process with the following conditions:

- 1) The applicant must clean the roadway(s) on a daily basis.
- 2) The applicant must require the contractor to secure the tailgate of the truck in a manner that water won't leak out onto Town Roads as part of transporting silt from the site to the disposal site.

If you have any questions, please do not hesitate to call.