From: <u>Aleksandra Moch</u>

To: fmjoe@georgetownfiredist.org; Wayne D"Avanzo

Cc: <u>Larkin, Elizabeth</u> **Subject:** Fw: 0 Mountain

Date: Wednesday, February 7, 2024 8:06:00 PM

CAREFUL-From outside - CHECK before you CLICK.

Dear Fire Marshal, Joe Paola

Thank you so much for your comments.

Wayne D'Avanzo, P.E., Fairfield County Engineering LLC had stated in his emailed, the notes are on the site plan. Please see his response below.

Thank you so much! Aleksandra Moch Environmental Consultant

---- Forwarded Message -----

From: wayne fairfieldce.com <wayne@fairfieldce.com> **To:** Aleksandra Moch <aleksandra_moch@yahoo.com> **Sent:** Wednesday, February 7, 2024 at 07:50:12 PM EST

Subject: Re: 0 Mountain

The culverts are HL 93 rated. That is for a 72,000 pound vehicle.

The turnaround is on the plan; it is a 26' radius.

Both are on the plan.

Best regards,

Wayne D'Avanzo, P.E.

Fairfield County Engineering LLC 60 Winfield Street Norwalk, CT 06855

Phone: 203 831 8005 (land line - Do not text)

Fax: 203 831 8006

From: Aleksandra Moch <aleksandra_moch@yahoo.com>

Sent: Wednesday, February 7, 2024 7:44 PM

To: wayne fairfieldce.com <wayne@fairfieldce.com>

Subject: Fw: 0 Mountain

Comments from the Fire Marshall.

---- Forwarded Message -----

From: fmjoe@georgetownfiredist.org fmjoe@georgetownfiredist.org <fmjoe@georgetownfiredist.org>

To: Santacroce, Stephen <stephen.santacroce@wiltonct.org>; Conklin, Mike

<mike.conklin@wiltonct.org>

Cc: Marc Nogid <mnogid@yahoo.com>; Larkin, Elizabeth <elizabeth.larkin@wiltonct.org>; Smeriglio,

Frank frank.smeriglio@wiltonct.org>; Aleksandra Moch <aleksandra_moch@yahoo.com>

Sent: Wednesday, February 7, 2024 at 03:59:15 PM EST

Subject: RE: 0 Mountain

I looked at the plans and I didn't see the weight carrying capacity of the gallies. The fire department tanker has a gross weight of 62,000 pounds. The reference to H-20 doesn't provide the information. I did not find any information relating to a turn around at the end of the driveway, (by the house). There has to be some means of being to turn the apparatus around, and it must capable of supporting the fire apparatus.

On 02/07/2024 10:21 AM EST Santacroce, Stephen <stephen.santacroce@wiltonct.org> wrote:

Good morning Mike, please see attached latest review letter.

Thank you,

Steve Santacroce, PE

Senior Civil Engineer

Town of Wilton

238 Danbury Road

Wilton, CT 06897

(203) 563-0154

From: Aleksandra Moch <aleksandra_moch@yahoo.com>

Sent: Wednesday, January 31, 2024 9:18 PM

To: Larkin, Elizabeth <elizabeth.larkin@wiltonct.org>

Cc: Santacroce, Stephen < Stephen.Santacroce@WILTONCT.ORG>;

fmjoe@georgetownfiredist.org; Conklin, Mike <Mike.Conklin@WILTONCT.ORG>; Marc

Nogid <mnogid@yahoo.com> **Subject:** Fw: 0 Mountain

CAREFUL - From outside - CHECK before you CLICK.

Hi Liz,

I hope all is well. Here we go again. Below are the revised maps and drainage reports. We believe all the concerns listed by Steve had been addressed. As requested, I have submitted the tree survey and inventory to the Tree Warden. I have not heard back from him. Joe is also cc on this email. His three requests included the driveway be wide enough, have needed capacity to support an emergency vehicle and there is a turning circle at the site entrance. All the concerns have been addressed and noted on the plans.

Please confirm receiving the attachments. We are looking forward to Steve's and Joe's responses.

Thank you for all your help.

Regards,

Aleksandra Moch

Environmental Consultant

---- Forwarded Message -----

From: wayne fairfieldce.com < wayne@fairfieldce.com >

To: Aleksandra Moch aleksandra_moch@yahoo.com>

Sent: Wednesday, January 31, 2024 at 08:59:17 PM EST

Subject: 0 Mountain

Hi Aleks

Please find pdfs of plans and reports attached.

Best regards,

Wayne D'Avanzo, P.E.

Fairfield County Engineering LLC

60 Winfield Street Norwalk, CT 06855

Phone: 203 831 8005 (land line - Do not text) Fax: 203 831 8006