

**WILTON PUBLIC WORKS
DEPARTMENT**

(203) 563-0153



**TOWN HALL ANNEX
238 Danbury Road
Wilton, Connecticut 06897**

TO: Mike Conklin,
Environmental Affairs

FROM: Frank Smeriglio, PE,
Assistant Director of Public Works/Town Engineer

DATE: Thursday, September 9, 2021 *FS*

Cc: Michael Wrinn – Director of Planning & Zoning
Craig Flaherty (via e-mail)

RE: **863-875 Danbury Road, CT Humane Society - Wilton CT –
WET #2724**

This is written in response to supplemental information submitted to our attention regarding the proposed development at 863-875 Danbury Road. The supplemental information was submitted in response to our August 5, 2021 letter.

Based on the review at this time, The Department of Public Works has no objections with this project continuing with the approval process with the following conditions:

- 1) Based on a recent site walk, the existing 12" pipe and existing 15" pipe along with the adjacent wetland area may act as a detention basin as it receives (on-site and offsite) storm water from the west basin. Therefore, please adjust and resubmit the drainage report (existing and proposed conditions) to incorporate the condition. Also, verify that any water overtopping the headwalls will not erode the soil as it flows to the downstream channel (or potentially add appropriate armoring).
- 2) The plans and drainage report shall be submitted to the State so that they have the opportunity to review drainage analysis and site plans as it relates to their storm drainage infrastructure and roadway on Route 7.
- 3) Prior to the issuance of Certificate of Occupancy, the Design Engineer shall provide As-built drawing and certification letter indicating that the project was built in accordance with the design plans.

If you have any questions, please do not hesitate to call.