

**From:** [wayne@fairfieldce.com](mailto:wayne@fairfieldce.com)  
**To:** [Larkin, Elizabeth](#); [Aleksandra Moch](#); [Marc Nogid](#)  
**Cc:** [Conklin, Mike](#)  
**Subject:** Re: 0 Mountain Rd driveway  
**Date:** Friday, January 12, 2024 8:25:07 AM

---

CAREFUL - From outside - CHECK before you CLICK.

HL 93 loading supports an HS 44 vehicle; a triaxle semitrailer of a total of 72,000 pounds.

The turnaround is shown on the revised plans and provides a 26' radius, which is the turning radius of a HS 44 vehicle.

Best regards,

Wayne D'Avanzo, P.E.

Fairfield County Engineering LLC  
60 Winfield Street  
Norwalk, CT 06855

Phone: 203 831 8005 (land line - Do not text)  
Fax: 203 831 8006

---

**From:** Larkin, Elizabeth <[elizabeth.larkin@wiltonct.org](mailto:elizabeth.larkin@wiltonct.org)>  
**Sent:** Friday, January 12, 2024 8:21 AM  
**To:** Aleksandra Moch <[aleksandra\\_moch@yahoo.com](mailto:aleksandra_moch@yahoo.com)>; Marc Nogid <[mnogid@yahoo.com](mailto:mnogid@yahoo.com)>; wayne@fairfieldce.com <[wayne@fairfieldce.com](mailto:wayne@fairfieldce.com)>  
**Cc:** Conklin, Mike <[Mike.Conklin@WILTONCT.ORG](mailto:Mike.Conklin@WILTONCT.ORG)>  
**Subject:** FW: 0 Mountain Rd driveway

Hi Aleks, Marc, and Wayne,

Please see the below email received from the Georgetown Fire Marshal relating to the Old Driftway 0 Mountain Road Application.

Thank you,  
Liz  
203-563-0180

---

**From:** [fmjoe@georgetownfiredist.org](mailto:fmjoe@georgetownfiredist.org) [fmjoe@georgetownfiredist.org](mailto:fmjoe@georgetownfiredist.org)  
<[fmjoe@georgetownfiredist.org](mailto:fmjoe@georgetownfiredist.org)>  
**Sent:** Thursday, January 11, 2024 1:03 PM  
**To:** Conklin, Mike <[Mike.Conklin@WILTONCT.ORG](mailto:Mike.Conklin@WILTONCT.ORG)>

**Subject:** ) Mountain Rd driveway

C A R E F U L - From outside - CHECK before you CLICK.

Good afternoon Mike,

I e-mailed Daphne re my comments regarding the proposed driveway for 0 Mountain Rd and she recommended me to forward them to you.

This is a copy of my e-mail:

***Good Morning Daphne,***

***I understand that there is a zoning meeting tonight re 0 Mountain Rd driveway. The engineer sent out a letter dated December 13, 2023 where he stated that the box culverts are HL 93 rated, greater than the gross weight of the fire truck. I think we should have an actual numerical amount that the culverts can carry.***

***He also mentioned that a turn around will be provided. We need specifics on the configuration of the turn around and the ability for the surface support the vehicle(s) weight.***

***I***

If you have any question please feel free to call mee, 203-544-8933.

Joe Paola