

1. HANDRAILS SHALL HAVE A MINIMUM CLEAR WIDTH OF 36" BETWEEN EDGE OF RAILS.

- 2. TOP RAIL OF HANDRAILS SHALL BE A MINIMUM OF 34" AND A MAXIMUM OF 38" ABOVE SURFACE OF RAMP.
- 3. IF CONCRETE EDGE PROTECTION (2" HIGH MINIMUM) IS NOT PROVIDED, A FOOT BAR/RAIL MUST BE PROVIDED. THE FOOT BAR/RAIL SHALL BE AT AN ELEVATION NO GREATER THAN 4" FROM THE FINISH GROUND SURFACE.

DETAIL

MISCELLANEOUS IMPROVEMENTS - ADA COMPLIANT HANDRAILS

MI-HR