

White, Daphne

From: Grosso, Rocco
Sent: Wednesday, April 5, 2023 1:43 PM
To: White, Daphne; Wrinn, Michael
Subject: FW: i.Park Hotel - Special Permit / Site Plan Application

Please see below.

From: Grosso, Rocco
Sent: Tuesday, January 31, 2023 09:37
To: 'Lauren Calabria' <lcalabria@nationalresources.com>
Cc: jim.blanchfield@wiltonct.org; Wrinn, Michael <Michael.Wrinn@WILTONCT.ORG>
Subject: RE: i.Park Hotel - Special Permit / Site Plan Application

Hi Lauren.

We've completed the site plan review are looking for several changes and additions.

Please provide aerial fire apparatus access in the front of the hotel in accordance with International Fire Code (2021) Sec. D105. The Fire Department Connection for the sprinklers should be located to the right of the main entrance with a fire hydrant at the landscaped area to the right of the entrance and another in the landscaped area near the south exit stairs. Please let me know if you'd like to discuss. Thanks.

Rocco Grosso
Fire Marshal
[Wilton Fire Department](#) | Office of the Fire Marshal
236 Danbury Road
Wilton, CT 06897
Phone (203) 834-6249

From: Grosso, Rocco
Sent: Wednesday, January 25, 2023 09:15
To: 'Lauren Calabria' <lcalabria@nationalresources.com>
Subject: RE: i.Park Hotel - Special Permit / Site Plan Application

Hi Lauren.

I'm working on this with the fire chief. Can you tell us what the proposed construction type will be? Thanks.

-Rocco

Rocco Grosso
Fire Marshal
[Wilton Fire Department](#) | Office of the Fire Marshal
236 Danbury Road
Wilton, CT 06897
Phone (203) 834-6249