

-----Original Message-----

From: fmjoe@georgetownfiredist.org <fmjoe@georgetownfiredist.org>

Sent: Thursday, September 9, 2021 12:32 PM

To: White, Daphne <Daphne.White@WILTONCT.ORG>

Subject: Re: FW: P&Z Links - P&Z Agenda - Sept 13, 2021

CAUTION: This email came from outside the Town network. Is it authentic? Don't click until you are sure.

Daphne,

A cursory review of the site plans looks acceptable with respect to Fire Department access. I would suggest that the developers review Chapter 18, Section 18-1 to 18.2.4.2.6 of the 2018 Connecticut State Fire Prevention Code, (based on the 2015 edition of NFPA-1 and the Ct supplements), regarding the requirement for access to buildings and turning radius of fire apparatus.

If you have any questions please feel free to call