

TOWN OF WILTON
ADDENDUM NO. 3

RFP #2022-11

ISSUE DATE: January 13, 2023



**Request for Proposal to Replace
Arrowhead Road Bridge - Bridge #05501**

This addendum is being issued to answer the following question regarding the RFP to Replace Arrowhead Road Bridge.

Question - If pre-auguring is required, please confirm pay limits will be from the bottom of footing to the rock elevation?

Response – As indicated in Note 5 of Dwg S-06, pre-auguring may be utilized to facilitate pile driving between bottom of footing and bedrock if obstructions are present. The actual limits of pre-auguring, if deemed to be required at the site, shall be determined by the Engineer based on field conditions. An allowance of 400LF has been included for pre-auguring piles in the contract documents

Addendum No. 3 is being issued to all potential bidders to provide the items and attachments set forth herein which shall act to qualify, clarify or otherwise modify the Documents previously issued regarding the above referenced project. These items, whether of omission, addition, substitution, or clarification, shall be incorporated into the proposals submitted by all proposers, and receipt of this document and its attachments must be acknowledged in the space provided on the Proposer's Schedule of Prices Form. Failure to do so may subject the Proposer to disqualification.

Frank Smeriglio, PE

Director of Public Works, Town Engineer

Town of Wilton