

**Wilton Station Pedestrian Walkway  
Addendum No. 2**

**TO:** Prospective Bidders  
**FROM:** Joseph Canas, PE, LEED AP, CFM  
**COPY:** Frank Smeriglio, PE, Director of Public Works, Town of Wilton  
**DATE:** April 20, 2022

---

The following clarification has been issued:

1. All piles shall be HP 12 x 63. They are incorrectly shown on S-2 as HP 8 x 36.